

Village of Bald Head Island Utilities Department

Contractors Tap Information Sheet

- All residential and non-residential water and sewer connection charges must be paid (in full) prior to sheathing inspection.
- All building contractors must give (30) days notification of the date water or sewer services will be required.
- Contractor must contact the Village Utilities Department if decision input on the Sewer pump, control panel and water meter location is desired.
- Clear access to the site must be made available by the contractor to facilitate the water and/or sewer system installation.
- Sewer pump system requires a 20 Amp (double pole) breaker and a 220-240 Volt power supply to the pump control panel (building contractor responsibility).
- Double or RPZ (testable) check valves are required for most commercial facilities, irrigation and waterfront property taps. Contact the Utilities Department for additional information.
- Check valves are required for all residential taps. Check valves are provided by Village Utilities Department (residential only).
- Water service consumers are not permitted to connect to any plumbing that may have the potential to produce wastewater, unless the plumbing is attached to an approved and operational sewer system.
- All potential sewer customers must stop sewer discharge piping installation approximately three (3) feet short of pump systems. The final three foot connection to the Village owned sewer system will be the responsibility of Village Utilities staff.
- If any damage occurs to the sewer pump system or water metering equipment due to material deliveries, construction access or other negligence, the building contractor will be held liable for the repair cost.

If you have any further questions, comments or concerns, please contact The Village of Bald Head Island Utilities Department at 457-7350.